

SECTION 3

3.11 CURB STOPS, VALVES, AND VALVE BOXES:

A curb stop or gate valve of the same size as the service line and conforming to the following standards shall be installed on every service line at a point at or near the property line. Curb stops 2 inches and smaller shall conform to AWWA C800 and MS-21. Gate valves 3 inches and larger shall conform to 8.12 and MS-4.

All buried valves and curb stops shall be equipped with a cast iron valve box, Buffalo type, and large oval base. See 6.12 for valve boxes and 6.40 for curb stop services boxes.

See 6.23 for requirements on valves used with meters.